# **EU Declaration of Conformity**

Henry Technologies hereby declare under our sole responsibility that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations (European Directive 2014/68/EU)

### Description of Pressure Equipment: Suction Line Accumulators Models covered: (Cat I) S-7057, S-7061 (Cat II) S-7063, S-7065, S-7721, S-7722, S-7725, S-772

(Cat II) S-7063, S-7065, S-7721, S-7722, S-7725, S-7726 & S-7731 (Including Products with HE & HP Siffix).

## Conformity & Assessment Procedure Followed:

Category	Cat 1	Cat II
Module	Α	D1
Certificate	N/A	CE-0041-PED-D1-HEN-001-18-GBR
PV	>50 - ≤ 200	>200 - <1000

Classified for	Group 2 Gases
Design Pressure	31.0 Bar
Maximum Op. Temp	+80° C
Minimum Op.Temp	-30° C

The following transposed European standards and other technical specifications have been used:

UL 207 – AD Merkblätter

#### Notified Body: Bureau Veritas UK Ltd.

2<sup>nd</sup> Floor Atlantic House Atlas Business Park Wythenshawe Manchester M22 5PR Notified Body identification No. **0041** 

Signed: Ronnie Crancher

Quality Manager

Date: 12/11/18



#### (Responsible Person - Name and actual Title)

1 DOC 048 Rev A18

A subsidiary of Henry Group Industries Limited