

ROBA METALS B.V  
 ZOMERDIJK 27-33  
 3402 NL AA IJSSELSTEIN(NL)

**INSPECTION CERTIFICATE**  
**Type 3.1 acc. EN 10204**

**Certificate No : 1000410755**  
**Delivery No : 0085195711**

**DATE: 10.10.2019**

Customer	ROBA METALS B.V		
Cust's Ref No	PO-0022175-2/88th	Cust's Part No	
Our Order No	1200101459 / 50	Quantity	2.400,00 MTR
		Inspection Lot	020000578011

Designation	CuT m 018,000x1,00x5000 JE HSM R		
according to	EN 12735-1 R250 PED 2014/68/EU & CUSTOMER REQUIREMENTS		
Material	Cu-DHP		
Chem. Anal.:	CU>99,90-P:0,015-0,040	OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	>=17,910	17,970 - 18,000	2
ODmax	mm	<=18,090	18,010 - 18,060	2
ODav	mm	17,960 - 18,040	18,005 - 18,015	2
Smin	mm	>=0,850	0,910	2
Smax	mm	<=1,150	0,950	2
Sav	mm	0,919 - 0,938	0,930	2
LENGTH	mm	5000 - 5008	5005	2
WGHT/m	kg/m	0,4379 - 0,4485	0,4420	2
Rm	N/mm <sup>2</sup>	>=250,0	314,6 - 319,5	2
A50	%	>=30,0	35,5 - 38,6	2
EXPANSION	%	>=30,0	OK	2
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,06 - 0,10	2
ECT EN 1971	%	100	OK	-

**DECLARATION OF COMFORMITY**

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

11.10.2019

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017

e-mail: info@halcor.com  
 website: www.halcor.com  
 VAT number: EL094061318

**Offices @ Copper Tube Plant (Mailing Address)**  
 62<sup>nd</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 48111, Fax: +30 22620 48911

**Foundry**  
 60<sup>th</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 53479, Fax: +30 22620 53925

**Domestic Sales Dept**  
 252 Pireos str.  
 GR-17778, Tavros, Athens, GREECE  
 Tel.: +30 210 4898111, Fax: +30 210 4898397