



Ctra. C-17, Km 73,5, Colonia Lacambra
08509 Les Masies de Voltregà (BCN)

CERTIFICATE OF COMPLIANCE

(EN 10204 type "3.1")



COSTUMER: ROBA METALS B.V.
ADDRESS : ZOMERDIJK, 17 - 33
3402 mj - IJSSELSTEIN
UTRECCHT - HOLLAND

SHIPMENT DATE : 07/03/2011

WE CERTIFY that the goods detailed hereon fulfil with the following standard : **EN 12735-1**

Type matériel : Cu-DHP	Product type : ACR COPPER TUBE
Type of tube: Seamless rolund copper tubes for air conditioning and refrigeration. Part 1: Tubes for paiping systems.	Chemical analysis : Cu + Ag min. 99,90% P : 0,015 ÷ 0,040%

DELIVERY NOTE Nº	RELATION OF MATERIAL				SIZE CONTROL						MECHANICAL PROPERTIES			
	NOMINAL SIZE mm.	TEMPER	MTS. total	BATCH Nº	DIAMETER			WALL THICKNESS			Tensile Strenght N/mm ²	Elong. A5 %	Hardness HV5	Total Carbon mg/dm ²
					Min. mm.	Mean mm.	Max. mm.	Min. mm.	Mean mm.	Max. mm.				
					Standard Tolerances									
					9,48	9,48÷9,56	9,56	0,69	0,69÷0,83	0,83	min 250	min 30%	75 ÷ 100	max 0,38
2011/01/000871	Ø 3/8"x 0,76	Half-hard (R250)	6.000	7794	9,53	9,54	9,55	0,69	0,74	0,78	268	30	80	0,17
			TOTAL	6.000										

These goods have been produced under a certified Quality Assurance System.

Les Masies de Voltregà (Spain),

07/03/2011

LA FARGA TUB, S.L.
(Quality Dpt.)