



March 5, 2008

PRODUCT BULLETIN

WORKING & BURST PRESSURE FOR PACKLESS REFRIGERANT HEAT EXCHANGERS – HXR & LHXR

PACKLESS PRODUCTS HXR & LHXR ARE APPROVED FOR FOLLOWING LISTED BURST AND WORKING PRESSURES.

MODEL #	ULTIMATE BURST PRESSURE - PSI	WORKING ** PRESSURE - PSI	WORKING PRESSURE - BAR
HXR-25	2250	643	43.7
HXR-50	2250	643	43.7
HXR-75	2300	657	44.7
HXR-100	2250	643	43.7
HXR-150	2250	643	43.7
HXR-250A	2000	571	38.8
HXR-350A	2000	571	38.8
HXR-500	1700	486	33.0
LHXR-15	1510	431	29.3
LHXR-20	1510	431	29.3
LHXR-25	1510	431	29.3
LHXR-30	1510	431	29.3
LHXR-35	1510	431	29.3
LHXR-40	1510	431	29.3
LHXR-50	1510	431	29.3
LHXR-60	1600	457	31.1
LHXR-80	1600	457	31.1

\*\* 1. NOTE THAT THE FACTOR OF 3.5 IS APPLIED TO ARRIVE AT THE LISTED BURST PRESSURE. FOR EXAMPLE 
$$\text{WORKING PRESSURE} = \frac{\text{BURST PRESSURE}}{3.5}$$

2. THESE BURST PRESSURE NUMBERS ARE ESTABLISHED BASED ON THE STRENGTH TEST CONDUCTED BY UNDERWRITERS LABORATORY (U.L.).

CONTACT US AT (254) 666-7700 OR [SALES@PACKLESS.COM](mailto:SALES@PACKLESS.COM) FOR QUESTIONS OR IF YOU NEED ADDITIONAL INFORMATION.

P.J. DESAI  
DIRECTOR OF MARKETING & PRODUCT ENGINEERING