







Installation guide

Electric Expansion Valve


Types AKV 15, AKVA 15

068R9548



068R9548

Refrigerants: AKV R744, R22/R407C, R404A/R507, R410A, R134a, R407A, R407F, R23, R448A, R449A, R449B, R452A, R513A, R450A, R422B, R422D AKVA R717, R744, R22/R407C, R404A/R507, R410A, R134a, R407A, R23, For other refrigerants, please contact Danfoss.	Max. working pressure: AKV 15: PS/MWP = 46 barg / 667 psig AKVA 15: PS/MWP = 42 barg / 610 psig Max. test pressure: $P_e = 52$ barg / 754 psig Max. differential pressure: MOPD = 22 bar / 319 psi
Media temperature range: Min. t_{media} -50 °C / -58 °F Max. t_{media} 60 °C / 140 °F	Ambient temperature range: Min. t_{amb} -40 °C / -58 °F Max. t_{amb} 50 °C / 120 °F
	
AKV 15 	AKVA 15 
 (en-gb) Do not insulate (da) Må ikke isoleres (de) Nicht isolieren (fr) Ne pas isoler (es) No encerrar para evitar condensación	 Warning Never switch on power to the coil when the coil is dismounted from the valve. Otherwise the coil may be damaged and there is risk of injuries

Service



AKVA 15 only



en-gb	da	de	fr	es
The gasket must be exchanged, if the valve is dismantled.	Pakningen skal skiftes, hvis ventilen adskilles.	Bei Zerlegung des Ventils muß die Dichtung ausgetauscht werden.	Changer le joint chaque fois que la vanne est démontée.	Es preciso cambiar la junta si se desmonta la válvula