

## *EU Declaration of Conformity*

Henry Technologies hereby declare under our sole responsibility that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations (European Directive 2014/68/EU)

### **Description of Pressure Equipment: Safety Relief Valves**

**Conformity and Assessment Procedure followed:**

**Product Category: Cat IV**

**Modules: B + D**

<b>B5344 Standard Pressure Settings in Barg.</b>					
<b>20.8</b>	<b>22.4</b>	<b>24.1</b>	<b>24.8</b>	<b>27.6</b>	<b>31.0</b>

<b>B567LE, B5346 Standard Pressure Settings in Barg.</b>							
<b>10.3</b>	<b>14.0</b>	<b>16.2</b>	<b>20.7</b>	<b>24.1</b>	<b>24.8</b>	<b>27.6</b>	<b>31.0</b>

**Design Strength Test Pressure = 155 Bar (Type Approval)**

<b>Model no.</b>	<b>Orifice size</b>	<b>Type Certificate no.</b>	<b>Fluid Group</b>
<b>B5344-CE</b>	<b>0.500</b>	<b>CE-0041-PED-B-HEN-001-09-GBR rev B</b>	<b>1 &amp; 2</b>
<b>B567LE</b>	<b>0.500</b>	<b>CE-0041-PED-B-HEN-002-13-GBR</b>	<b>1 &amp; 2</b>
<b>B5346</b>	<b>0.703</b>	<b>CE-0041-PED-B-HEN-001-14-GBR</b>	<b>1&amp; 2</b>

<b>Classified for</b>	<b>Fluid Group 1 &amp; 2</b>
<b>Maximum Op. Temp</b>	<b>+130°C</b>
<b>Minimum Op. Temp.</b>	<b>-20°C</b>

The following transposed European standards and other technical specifications have been used: **ASME VIII Division 1**



**Notified Body:**

The Notified Body which inspected the manufacturer's quality assurance system:

Bureau Veritas UK Ltd  
Parklands  
Wilmslow Road  
Didsbury  
Manchester M20 2RE

Notified Body identification No. **0041**

Signed

Quality Director Date: 20.6.16

(Responsible Person - Name and actual Title)